

SERTIFIKAT O KONTROLISANJU
INSPECTION CERTIFICATE

 Broj / Number: **C 1206**

 Strana / Page: **2/2**
Prilog A /
Annex A

 oznaka - tip - serija /
 mark - type - series :

ITEM: 089

oznaka - tip - serija / mark - type - series:	tehničke karakteristike / technical characteristics :	kratak opis / short description :
ITEM: 089	<ul style="list-style-type: none"> ○ priključne mere/ connection measures G 1/2 "(M/ F); ○ nazivni pritisak podešavanja/ nominal pressure setting: 9.0 bar 	<u>materijal/material:</u> <ul style="list-style-type: none"> ○ telo/body: mesing CuZn39Pb2/ brass CuZn39Pb2; ○ opruge/ springs: čelična žica – nerđajući čelik AISI 302/ steel wire – Stainless steel AISI 302; ○ zaptivke/seals: gume NBR i VMQ/ rubber NBR and VMQ
Napomena / Note :		

INSPECTION CERTIFICATE
SERTIFIKAT O KONTROLISANJU
INSTITUT
"MIHAJLO PUPIN"
CENTAR ZA
GASNU TEHNIKU
 Volgina 15
 BEOGRAD
 SRBIJA
 tel: +381 11 2772 151
 fax: +381 11 2781 029
 impcgt@labtel.imp.bg.ac.rs